

Energy performance certificate (EPC)

GOWAN HOUSE UNIT 24H MANDALE PARK BELMONT INDUSTRIAL ESTATE DURHAM DH1 1TH	Energy rating <div>C</div>	Valid until: 12 October 2030 Certificate number: 1686-6293-1246-0772-7109
--	-------------------------------	--

Property type

B8 Storage or Distribution

Total floor area


306 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy efficiency rating for this property

This property's current energy rating is C.



Properties are also given a score. The larger the number, the more carbon dioxide (CO2) your property is likely to emit.

How this property compares to others

Properties similar to this one could have ratings:

If newly built

26 | B

If typical of the existing stock

76 | D

Properties are given a rating from A+ (most efficient) to G (least efficient).

Breakdown of this property’s energy performance

Main heating fuel	Grid Supplied Electricity
Building environment	Heating and Natural Ventilation
Assessment level	3
Building emission rate (kgCO2/m2 per year)	35.61
Primary energy use (kWh/m2 per year)	211

Recommendation report

Guidance on improving the energy performance of this property can be found in the [recommendation report \(/energy-certificate/7982-7516-4468-9396-1626\)](#).

Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

Assessor contact details

Assessor's name	George Smith
Telephone	07756529827
Email	gsmith0_1@hotmail.com

Accreditation scheme contact details

Accreditation scheme	Stroma Certification Ltd
Assessor ID	STRO000595
Telephone	0330 124 9660
Email	certification@stroma.com

Assessment details

Employer	DG Surveys
Employer address	14 Markington Drive, Ryhope, Sunderland SR2 0LB
Assessor's declaration	The assessor is not related to the owner of the property.
Date of assessment	11 October 2020
Date of certificate	13 October 2020
